SU-VASTIKA SYSTEMS PVT. LTD.

Lithium Battery Installation Safety Compliance Questionnaire

Customer Name: _____ Battery Model: _____
Site Address: _____
Installation Date: _____ Inspection Date: _____

S.No	Safety Requirement	Yes	No
1	Covered, dry, ventilated location protected from sun/rain/heat?	■	■
2	Installed on stable, non-combustible surface?	■	■
3	Installed by qualified electrician with copper earthing and Neutral-Earth <5V?	■	■
4	Input MCB located near UPS/ESS and accessible?	■	■
5	Cables secure, undamaged and protected from rodents?	■	■
6	Adequate ventilation/exhaust fan available?	■	■
7	Used only with approved UPS/Inverter/Charger?	■	■
8	Battery not opened, modified or tampered?	■	■
9	Class D fire extinguisher available nearby?	■	■
10	Routine inspection shows no swelling, leakage or overheating?	■	■

Scoring: 10 = Fully Compliant | 8-9 = Minor Corrections | 6-7 = Corrective Action Required | <6 = Non-Compliant

Remarks:

_____

Customer Signature: _____ Inspector: _____

Su-vastika Customer Support
Phone: 9711774744, 18002024423
Email: info@suvastika.com
Address: Ghamroj, Near Toll Plaza, Sohna Road, Gurgaon-122102
Website: www.suvastika.com